

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

Control Switch Model 07-1501abef
Control Switch Model 07-2501cdef

- a = Contact / lead material 1, 2, 3, 5, 6, or 7.
- b = Length of leads (in m).
- c = Contact / lead material 5, 6, or 7.
- d = Length of cable (in m) 0 thru 9.
- e = Contact element 10, 20, or 30.
- f = Actuator 00, 01, 03, 63, or 99.

Equipment Ratings: Explosionproof for Class I, Division 2, Groups A, B, C, and D

Manufactured by: BARTEC Componenten und Systeme GmbH
Max-Eyth-Straße 16
D-97980 Bad Mergentheim
Germany

This certifies that the equipment described has been found to comply with the following Factory Mutual Research Corporation Approval Standards:

Approval Standard Class 3600 - 1989
Approval Standard Class 3615 - 1989

Approval Job Identification: 1Z2A3.AE Approval Granted : October 26, 1995

Subsequent Revision Reports / Date Approval Amended

None

Factory Mutual Research Corporation



Roger P. Lutfy
Electrical Section Manager
Approvals Division

07/13/98

Date