



Supplement to Certificate of Compliance

Certificate: 2515401

Master Contract: 180267

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
70010167	Dec 4, 2014	Update to Report 2515401 to include new devices and implement new approval documentsc
2625894	May 15, 2013	Update to Report 2515401 to include new enclosure TNCN series and Fieldbus Indicator
2515401	Jul 26, 2012	CSAc-us Certification of Control Station as Class I Zone 1 Ex/AEx de ia/ib [ia/ib]mb q IIA/IIB/IIC, tD [ia/ib]A21 IP65 T80 C, T95 C, T 130 C; Degrees of Protection IP54 Gas/IP65 Dust

History

2625894	May 15, 2013	Update to Report 2515401 to include new enclosure TNCN series and Fieldbus Indicator
2515401	Jul 26, 2012	CSAc-us Certification of Control Station as Class I Zone 1 Ex/AEx de ia/ib [ia/ib]mb q IIA/IIB/IIC, tD [ia/ib]A21 IP65 T80 C, T95 C, T 130 C; Degrees of Protection IP54 Gas/IP65 Dust