



中国国家强制性产品认证证书



证书编号: 2020322313000818

认证委托人名称: 博太科防爆设备(上海)有限公司
 认证委托人地址: 上海市闵行区浦江高科技园F区新骏环路188号7号楼101、401
 生产者名称: BARTEC GmbH
 生产者地址: Max-Eyth-Str. 16 97980 Bad Mergentheim Germany
 生产企业名称: BARTEC GmbH
 生产企业地址: Max-Eyth-Str. 16 97980 Bad Mergentheim Germany

产品名称: 穿芯线缆
 系列、规格、型号: 07-91 系列、57-91 系列
 标准: GB 3836.1-2010、GB 3836.2-2010

上述产品符合强制性产品认证实施规则 CNCA-C23-01:2019 的要求, 特发此证。

发证日期: 2020年8月27日 有效期至: 2025年8月26日

首次发证日期: 2020年8月27日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批准:



上海仪器仪表自控系统检验测试所有限公司

<http://www.sitias.com.cn>

中国·上海·漕宝路103号200233

电话: +86 21 64510844

S 0000857



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322313000818

APPLICANT: BARTEC Explosion Proof Appliances (Shanghai) Co. Ltd
ADDRESS: 101, 401, New Building 7, No. 188, Xinjun Ring Rd., Shanghai
 Pujiang Hi-Tech Park(Pu Dong Area), Minhang
 District, Shanghai China

MANUFACTURER: BARTEC GmbH
ADDRESS: Max-Eyth-Str. 16 97980 Bad Mergentheim Germany
FACTORY: BARTEC GmbH
ADDRESS: Max-Eyth-Str. 16 97980 Bad Mergentheim Germany

PRODUCTNAME: Line bushing
SERIES,SPECIFICATION,MODEL: 07-91 series 57-91 series
STANDARDS: GB 3836.1-2010、 GB 3836.2-2010

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Valid from:August 27, 2020

Valid until: August 26, 2025

Date of original certification:August 27, 2020

The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL:

Xu JianPing



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitiias.com.cn>

Building 9,103 Cao Bao Road, Shanghai 200233,China

Tel: +86 21 64510844

S 0000499



中国国家强制性产品认证证书



证书编号：2020322313000818

附件

产品名称：穿芯线缆

型号规格：07-91 *ab - cde / f* 其中
a 为套管设计代码，可为0~9、A；
b 为额定电压代码，可为0~5、8、9；
c 为线缆代码，可为0~5，A~H、J~N、P~Z
d 为导线芯数代码，可为00~99；
e 为套管尺寸代码，可为0~9、C~H、K、L、R、S；
f 为与防爆无关的代码，具体见说明书

57-91 *ab - cde / f* 其中
a 为套管设计代码，可为0~8、A；
b 为光纤类型，可为A、C、K、Z；
c 为光纤规格代码，可为0~3、9、R~Z
d 为光纤芯数代码，可为00~47
e 为套管尺寸代码，可为0~9、C~H、K、L、R、S；
f 为与防爆无关的代码，具体见说明书；

防爆标志：Ex d IIC Gb

电气参数：产品最大绝缘电压6000V，最大额定电流644A。

批准：



上海仪器仪表自控系统检验测试所有限公司