



中国国家强制性产品认证证书



证书编号: 2020322304001095

认证委托人名称: 博太科防爆设备(上海)有限公司
 认证委托人地址: 上海市闵行区浦江高科技园F区新骏环路188号7号楼101、401
 生产者名称: BARTEC GmbH
 生产者地址: Max-Eyth-Str. 16 97980 Bad Mergentheim Germany
 生产企业名称: BARTEC GmbH
 企业地址: Max-Eyth-Str. 16 97980 Bad Mergentheim Germany

产品名称: 控制、开关和指示模块
 系列、规格、型号: 07-33 系列
 标准: GB 3836.1-2010、GB 3836.2-2010、GB 3836.3-2010、
 GB 3836.4-2010、GB 12476.1-2013、GB 12476.4-2010、
 GB 12476.5-2013

上述产品符合强制性产品认证实施规则 CNCA-C23-01:2019 的要求, 特发此证。

发证日期: 2020年9月7日 有效期至: 2025年9月6日

首次发证日期: 2020年9月7日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批准:



上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322304001095

APPLICANT: **BARTEC Explosion Proof Appliances (Shanghai) Co. Ltd**
ADDRESS: 101, 401, New Building 7, No. 188, Xinjun Ring Rd., Shanghai Pujiang Hi-Tech Park(Pu Dong Area), Minhang District, Shanghai China

MANUFACTURER: BARTEC GmbH
ADDRESS: Max-Eyth-Str. 16 97980 Bad Mergentheim Germany

FACTORY: BARTEC GmbH
ADDRESS: Max-Eyth-Str. 16 97980 Bad Mergentheim Germany

PRODUCTNAME: Control, Switching and Display Module

SERIES,SPECIFICATION,MODEL: 07-33 series

STANDARDS: GB 3836.1-2010、 GB 3836.2-2010、 GB 3836.3-2010、 GB 3836.4-2010、 GB 12476.1-2013、 GB 12476.4-2010、 GB 12476.5-2013

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Valid from:September 7, 2020

Valid until: September 6, 2025

Date of original certification:September 7, 2020

The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL:

Xu JianPing



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitiias.com.cn>

Building 9,103 Cao Bao Road, Shanghai 200233,China

Tel: +86 21 64510844

S 0000746



中国国家强制性产品认证证书



证书编号：2020322304001095

附 件

产品名称：控制、开关和指示模块

型号规格：07-33 a 3-5 b c d / e, 其中
a 代表模块类型, 可选代码为: 2, 5, 6, 7。
b 代表模块版本, 可选代码为: 0~9, A~Z。
c 代表 LED 颜色, 可选代码为: 0~9, A~Z。
d, e 为与防爆无关代码。

防爆标志：Ex d e IIC T6 Gb, Ex d e ia IIC T6 Gb ,
Ex tD A21 IP66 T80℃, Ex iaD 21 tD A21 IP66 T80℃

电气参数：最大工作电压 400V, 最大工作电流 16A, 最高绝缘电压 690V。
当产品配用本安指示灯部件时, 本安参数为:
 $U_i=30V$, $I_i=150mA$, $P_i=1W$, $C_i=0 \mu F$, $L_i=0mH$ 。

批 准：



上海仪器仪表自控系统检验测试所有限公司