



中国国家强制性产品认证证书



证书编号：2020322304001711

认证委托人名称：博太科防爆设备（上海）有限公司
 认证委托人地址：上海市闵行区浦江高科技园F区新骏环路188号7号楼101、401
 生产者名称：BARTEC GmbH
 生产者地址：Max-Eyth-Str. 16 97980 Bad Mergentheim Germany
 生产企业名称：BARTEC GmbH
 生产企业地址：Max-Eyth-Str. 16 97980 Bad Mergentheim Germany

产品名称：控制箱
 系列、规格、型号：07-3 系列
 标准：GB 3836.1-2010、GB 3836.2-2010、GB 3836.3-2010、
 GB 3836.4-2010、GB/T 3836.7-2017、GB 3836.9-2014、
 GB 12476.1-2013、GB 12476.4-2010、GB 12476.5-2013

上述产品符合强制性产品认证实施规则 CNCA-C23-01:2019 的要求，特发此证。

发证日期：2020年9月22日 有效期至：2025年9月21日

首次发证日期：2020年9月22日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批准：



上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322304001711

APPLICANT: **BARTEC Explosion Proof Appliances (Shanghai) Co., Ltd.**
ADDRESS: New Building 7, 101、401 No. 188, Xinjun Ring Road, Pujiang Hi-Tech Park, Minhang District, Shanghai China

MANUFACTURER: BARTEC GmbH
ADDRESS: Max-Eyth-Str. 16 97980 Bad Mergentheim Germany

FACTORY: BARTEC GmbH
ADDRESS: Max-Eyth-Str. 16 97980 Bad Mergentheim Germany

PRODUCTNAME: Controller

SERIES,SPECIFICATION,MODEL: 07-3 Series

STANDARDS: GB 3836.1-2010、GB 3836.2-2010、GB 3836.3-2010、GB 3836.4-2010、GB/T 3836.7-2017、GB 3836.9-2014、GB 12476.1-2013、GB 12476.4-2010、GB 12476.5-2013

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Valid from: September 22, 2020

Valid until: September 21, 2025

Date of original certification: September 22, 2020

The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL:

Xu JianPing



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitiias.com.cn>

Building 9, 103 Cao Bao Road, Shanghai 200233, China

Tel: +86 21 64510844

S 0001040



中国国家强制性产品认证证书



证书编号: 2020322304001711

附件

产品名称: 控制箱

型号规格: 07-3 *a b c / d*

其中

a 代表适用的环境, 可选代码为: 1, 2。

b 代表外壳材质, 可选代码为: 01, 02, 03, 05, 06, 07, 08, 09, 10, 11, 12, 13, 14, 30, 31, 32, 33, 34, 35, 36, 37, 46, 47, 48, 49, 88, 89, 92, 93, 94, 95,, 99。

c 代表外壳尺寸, 可选代码为: 0706, 1206, 1706, 2506, 1208, 1209, 2208, 2209, 3608, 1609, 2609, 3609, 5609, 1709, 2011, 2018, 2811, 3311, 3318, 4011, 6011, 2911, 4111, 4118, 6111, 6118, 4211, 0805, 0807, 1105, 1107, 1605, 1607, 1905, 1907, 2305, 2307, 1209, 1212, 2209, 1609, 1612, 2609, 2713, 2813, 2913, 3609, 5609, 3415, 3419, 2013, 2512, 2516, 4012, 4016, 6012, 2015, 5030, 3515, 3519, 6815, 6819, 2515, 3020, 4020, 4112, 4116, 4120, 6020, 6030, 8130, 1006, 2006, 1506, 1508, 1510, 2510, 3008, 3510, 4008, 2008, 2010, 2012, 3108, 3010, 3112, 4010, 4013, 4015, 6112, 2616, 2620, 2015, 3012, 3016, 3121, 3815, 4115, 2716, 2720, 3021, 3816, 3821, 6022, 3022, 4216, 4021, 5016, 6016, 3516, 3520, 4221, 3822, 4121, 6021, 5516, 5520, 6121, 7630, 6030, 8030, 6416, 6420, 7416, 7420, 8130, 6025, 1240。

d 为与防爆无关代码。

防爆标志: Ex d e ia/ib [ib] ma/mb q IIA, IIB, IIC T6, T5, T4, T3 Gb, Ex d e ia/ib [ia Ga] ma/mb q IIA, IIB, IIC T6, T5, T4, T3 Gb, Ex tD [ibD] A21, T80°C, T100°C, T130°C IP6X, Ex tD [iaD] A21, T80°C, T100°C, T130°C IP6X

电气参数: 最高额定电压1000V, 最大额定电流160A。

批准:



上海仪器仪表自控系统检验测试所有限公司