



中国国家强制性产品认证证书



证书编号：2020322313000663

认证委托人名称：博太科防爆设备（上海）有限公司
 认证委托人地址：上海市闵行区浦江高科技园F区新骏环路188号7号楼101、401
 生产者名称：BARTEC GmbH
 生产者地址：Max-Eyth-Str. 16 97980 Bad Mergentheim Germany
 生产企业名称：BARTEC GmbH
 生产企业地址：Max-Eyth-Str. 16 97980 Bad Mergentheim Germany

产品名称：穿芯线缆
 系列、规格、型号：07-92 系列
 标准：GB 3836.1-2010、GB 3836.2-2010、GB 12476.1-2013、
 GB 12476.5-2013

上述产品符合强制性产品认证实施规则 CNCA-C23-01:2019 的要求，特发此证。

发证日期：2020年8月19日 有效期至：2025年8月18日

首次发证日期：2020年8月19日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批准：



上海仪器仪表自控系统检验测试所有限公司

<http://www.sitias.com.cn>

中国·上海·漕宝路103号200233

电话：+86 21 64510844

S 0000695



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322313000663

APPLICANT: BARTEC Explosion Proof Appliances (Shanghai) Co. Ltd
ADDRESS: 101, 401, New Building 7, No. 188, Xinjun Ring Rd., Shanghai Pujiang Hi-Tech Park(Pu Dong Area), Minhang District, Shanghai China

MANUFACTURER: BARTEC GmbH
ADDRESS: Max-Eyth-Str. 16 97980 Bad Mergentheim Germany
FACTORY: BARTEC GmbH
ADDRESS: Max-Eyth-Str. 16 97980 Bad Mergentheim Germany

PRODUCTNAME: Line bushing
SERIES,SPECIFICATION,MODEL: 07-92 series
STANDARDS: GB 3836.1-2010、GB 3836.2-2010、GB 12476.1-2013、GB 12476.5-2013

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Valid from: August 19, 2020

Valid until: August 18, 2025

Date of original certification: August 19, 2020

The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL:

Xu JianPing



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitilas.com.cn>

Building 9, 103 Cao Bao Road, Shanghai 200233, China

Tel: +86 21 64510844

S 0000394



中国国家强制性产品认证证书



证书编号: 2020322313000663

附件

产品名称: 穿芯线缆

型号规格: 07-92 **a b** - **c d e** / **f g h i** 其中
a 代表外套类型, 可选代码为: 0~4
b 代表引入口类型, 可选代码为: 0~8
c 代表线径, 可选代码为: A~H, J~N, P~W, Z
d 代表导线数量, 可选代码为: 01~49, 51~99, A0~A9, B0~B9, C0~C9, D0~D9, E1~E9
e 代表外套尺寸, 可选代码为: 1~9, D~G, L, R, S
g 代表设计类型, 可选代码为: A, B, D, E, U, V, X, Y
f, h, i 为与防爆无关代码

防爆标志: Ex d IIC T6/T5/T4 Gb,
 Ex tD A21 T80°C/T95°C/T130°C

电气参数: 最高额定电压1140V, 最大额定电流347A。

批准:



上海仪器仪表自控系统检验测试所有限公司